



① BRASS TAPPING SADDLE
REQUIRED FOR TAPS

SEE CURRENT APPROVED PRODUCT MANUFACTURERS
SHEET FOR APPROVED TYPES. (APPENDIX A)

① TAPPING SADDLE-
FOR D.I.P.
THREAD AWWA TAP

SEE CURRENT APPROVED PRODUCT MANUFACTURERS
SHEET FOR APPROVED TYPES. (APPENDIX A)

② CORPORATION STOP-
INLET AWWA THREAD
OUTLET CT PJ

SEE CURRENT APPROVED PRODUCT MANUFACTURERS
SHEET FOR APPROVED TYPES. (APPENDIX A)

③ METER SETTER -
INLET: COPPERTUBE PACK JOINT
OUTLET: COPPERTUBE PACK JOINT

SEE CURRENT APPROVED PRODUCT
MANUFACTURERS SHEET FOR
APPROVED TYPES. (APPENDIX A)

④ METER - TO BE INSTALLED BY THE CITY

⑤ METER BOX- SEE CURRENT APPROVED PRODUCT MANUFACTURERS
SHEET FOR APPROVED TYPES. (APPENDIX A)

⑥ 24" OF COPPER W/BE USED FOR TAIL PIPE AND FIP x CTPJ W/BE PROVIDED FOR CONNECTION

⑦ ALL ITEMS AS SPECIFIED OR APPROVED EQUAL

CITY OF SALISBURY, N.C. STANDARD DETAIL

DATE: OCTOBER 17, 2006

WATER SYSTEMS

NOT TO SCALE

3/4 & 1" METER CONNECTION

STANDARD

W-9